

# Official report of classification of fire performance of a material

Enisaged in article 5 decre of november 21, 2002



## N° CM-24-P-025/2

Valid 5 years as from 26/02/2024

### Material presents by :

**AKUSTIKSTOFF.COM**

Weschnitzmuehle 9

69509 MOERLENBACH

### Nature of the test

Electrical burner test  
Flame persistence flame  
Dripping test  
Artificial ageing

### Test report N° :

FE 24-0032-0185 et FE 24-0032-0193 off the 26/02/2024

### Trade mar :

**AKUSTIKSTOFF FR - Acoustics Cloth R - Tissu acoustique FR (imprimé)**

**Summary description:** *Details of the product description are provided in the supporting test report(s) cited above.*

- Kind of textile Tricot / Woven
- Composition 100% PES
- Mass per unit area 215+/-3% g/m<sup>2</sup>- Epaisseur: 0,7mm
- Kind of Fire retard Fibre spécial Flamex + traitement chimique azoté-phosphoré - 10 g/m<sup>2</sup>
- Color All colors (imprimé)
- Usual term: Walls hung covering, sheers, curtains,...

## Classement M1

*This classification is valid for any application for which the product is not subject to CE marking.*

**Durability of the classification :** Not limited

**Cleaning conditions :** Recommendation of Customer

**Scope:** This classification is valid for any application for which the product is not subject to CE marking

*This official report attest only characteristics of the sample submitted for testing and does not prejudice similar characteristics of products. It thus does not constitute a certificate of products within the meaning of the L. 115-27 article of the code of the consumption and the law of June 3rd, 1994. These conclusions relate only to the resistance/reaction to fire performance of the element that is the subject of the present classification report. They do not predjudge, in any case, other performances related to its incorporation into a work.*

Siège social  
10, rue Galilée  
S 81050 Champs-sur-Marne  
77447 Marne-La-Vallée Cedex 2  
Tél +33 (0)1 72 84 97 84

Bordeaux  
Allée de Boutaut – BP 227  
33028 Bordeaux Cedex  
Tél +33 (0)5 56 43 63 00

Siret 775 680 903 00132  
APE 7219Z  
Code TVA CEE FR 14 775 680 903

Champs-sur-Marne, 05/03/2024

Technicien d'essais du Laboratoire Feu

Cyril FLEURIER

Responsable des Laboratoires Essais et  
Mesures  
du Pôle AME

Nathalie SERRANT



Institut technologique FCBA : Forêt, Cellulose, Bois - construction, Ameublement | [www.fcba.fr](http://www.fcba.fr)

This document includes 1 page for the classification report and et 1 annexe de 4 pages.

Only full reproductions by photocopies of this classification report or of the entire classification report are authorized.  
and attached test report(s)

